



# Certificate of compliance

**Applicant:** Solamax Produktions GmbH  
Zur Schönhalde 10  
89352 Ellzee  
Germany

**Product:** Automatic disconnection device between a generator and the public low-voltage grid

**Model:** 17SHT  
20SHT  
22SHT  
25SHT  
28SHT  
30SHT

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with DIN VDE V 0126-1-1:2013-08 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

## Applied rules and standards:

**DIN VDE V 0126-1-1:2013-08; VDE V 0126-1-1:2013-08**

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** PVDE190402N011-1

**Certification Program:** NSOP-0032-DEU-ZE-V01

**Certificate number:** U19-0438

**Date of issue:** 2019-07-26



**Certification body**

Holger Schaffer



Certification body Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065  
A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH